

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1591:216

Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

DESIGN: Models DH200PLF and DH200RPLF Duct smoke detector units. Units consist of a housing, relay, electrical components, sampling and exhaust tubes and a listed detector head. Refer to the listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, air velocity rating and UL label.

APPROVAL: Listed as a duct detector when used with System Sensor's separately listed compatible fire alarm control units. Intended for use in HVAC systems having air velocities between 100-4000 ft/min. Also suitable for use as a stand alone unit where permitted.

XLF: 3240-1209:155

06-25-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 23, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager